

CERTIFICATE OF COMPLIANCE

Certificate Number E488372
Report Reference E488372-20220401
Date 2022-April-05

Issued to: Scientific Systems LLC
7924 Reco Avenue
Baton Rouge LA 70814 US

**This is to certify that
representative samples of** ROOM AIR CONDITIONERS FOR USE IN HAZARDOUS
LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E488372
Report Reference E488372-20220401
Date 2022-April-05

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Window or In-Wall Type Room Air Conditioner, Models WACX-1214, -1804, -2404 and -3604 for use in Class I, Division 2, Groups C and D, Hazardous Locations.

Window or In-Wall Type Room Air Conditioner, Models WACX-1214, -1804, -2404 and -3604, followed by RC-IBCD2 for use in Class I, Division 2, Group B, C and D, Hazardous Locations.

Standard

UL 484, Room Air Conditioners


CSA C22.2 No. 117-1970, Room Air Conditioners

UL 121201/ CSA C22.2 No. 213-17, UL 121201, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations,

CSA C22.2 No. 213-17, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations,

UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations

CSA C22.2 No. 30, Explosion-proof equipment,



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>