



Ordering Codes For Condensing Units

Compressor

CUXA	= semi (accessible) hermetic
CUXH	= hermetic
CUHO	= open drive
CUXS	= scroll
CUXS(2)	= dual scroll (or scroll with number indicating quantity)

Condenser

A	= Air Cooled
W	= Water Cooled, Standard
N	= Water Cooled, Cupro Nickel

Refrigerant

-22	= Refrigerant 22
-502	= Refrigerant 502
-134	= Refrigerant 134a
-62	= Refrigerant 62
-404	= Refrigerant 404A
-407C	= Refrigerant 407C
-410A	= Refrigerant 410A

Operating Temperature

-H	= High
-M	= Medium
-L	= Low

Nominal Horsepower

-0075	= 3/4
-0100	= 1
-1000	= 10

Power Configuration

	For 60 Herz	For 50 Herz
- A	= 115	
- B	= 208/230/1	- B(50) = 200/220/1
- C	= 208/230/3	- C(50) = 200/220/3
- 5	= 200/230/3	- 5(50) = 200/240/3
- D	= 460/3	- D(50) = 380/420/3
- E	= 575/3	- E(50) = 550/3
- Z	_____	- Z(50) = 220/240/1

Continued on other side



Ordering Codes For Condensing Units

Housing

- I = Industrial, Heavy Duty
- I (316SS) = Industrial, Heavy Duty, Type 316 Stainless Steel
- S = Standard Commercial
- N = Supplied without Housing

Disconnect Switch

- DS = Disconnect Switch supplied as separate item
- DSI = Disconnect Switch Installed
- FDI = Disconnect Switch w/ Circuit Protection, Installed
- ND = No Disconnect

Hazard Classification

- ID1 = NEC Class (I or II), Group (C,D,E,F, or G), and Division (1 or 2)
- NNN = Not for Hazardous Service (Not classified)

Additional Options

- /LAC = Low Ambient Controls, for operating when outdoor temperatures are below 55°F.
- /CC = SaveCoil 101 Dip applied and baked coil coating
- /BG = BLYGOLD PouluAL spray applied coil coating

EXAMPLE:

CUXH - A - 22 - H - 5 - D - I - DSI - ID1



**SCIENTIFIC
SYSTEMS
CORPORATION**